

Report on potential Electric Vehicle (EV) siting in Overton Main Car Park

Contractor: Mega Electrical North Wales Ltd

Please see below, brief notes post meeting with Carl Bellis (Contracts Director)

- The power supply is fine for a single EV station with two charging points, connecting to the existing supply in toilet block
- The meter would be split into toilets/EV, great for us as we can recharge costs to WCBC more easily. Note: minimal work needed for positioning as photo
- We may consider future proofing for further EV charging points (e.g. 8) by allocation a larger section of the Car Park. However, this would involve Scottish Power adding a further line to the electric supply, so more groundwork

